## Evaluation #

200223-H Revised

**Safety & Buildings Division** 201 West Washington Avenue P.O. Box 2658 Madison, WI 53701-2658

## **Wisconsin Building Product Evaluation**

Through-the-Wall A/C Units:

Manufacturer: National Comfort Products

539 Dunksferry Road Bethsalem, PA 19020

SCOPE OF EVALUATION: This review includes the cited Comm code requirements below in accordance with the current Wisconsin Building and Heating and Air Conditioning Code: s. Comm 64.21, Table 64.21 and s. Comm 64.22.

This review includes the cited International Mechanical Code (IMC) requirements below in accordance with the Wisconsin Amended IMC Code (effective 7/01/02): s. IMC 301.4[Comm 64.0301(2)], 301.5, 301.5.1, 301.7[Comm 64.0301(3)].

Approved Product(s): Trade Name: Comfort-Pack

CPG1838-A CPG1851-A CPG1864-A CPG2438-A CPG2451-A CPG2464-A CPG3051-A CPG3064-A CPG1238-A

\*

TESTS: The CPG Series package heating/cooling equipment was tested in accordance with the requirements of UL 1995, the Standard for Heating and Cooling Equipment, and ANSI Z21.47 by Intertek Testing Services. The units are certified by ETL.

<u>LIMITATIONS OF APPROVAL</u>: The CPG Series package heating/cooling equipment is designed and approved for through-the-wall installation only.

The CPG Series package heating/cooling equipment is not to be used for temporary heating of buildings or structures under construction.

The CPG Series package heating/cooling equipment shall be installed in accordance with their listing and the manufacturer's recommendations.

This approval will be valid through December 31, 2007, unless manufacturing modifications are made to the product or a re-examination is deemed necessary by the department.

The Wisconsin Building Products Evaluation number must be provided when plans that include this product are submitted for review.

**<u>DISCLAIMER</u>**: The department is in no way endorsing or advertising this product. This approval addresses only the specified applications for the product and does not waive any code requirement not specified in this document.

Revision Date: June 30, 2003 Approval Date: May 23, 2002 By:

> Lee E. Finley, Jr. Product/Material & Building Plan Review Integrated Services Bureau

200223-H.doc